



AAONE
PO BOX 91072 BURNHAMTHORPE ROAD
TORONTO ON M9C 5N5

Date: March 15, 2016
Account #: 58731
Journal #: 64902
Our File #: 5582387

Attn: EMMA SMITH

Re: Application for Design Registration

The design, as detailed in your, A2015-58, for a Fitting is accepted for registration as follows:

Registered To: ARMSTRONG INTERNATIONAL INC **CRN:** 0E10876.51

MAWT: 500 deg F

MAWP: 450 psig

Drawing #: CD1316, CD1317, C1118B, C1118C

Conditions Of Registration:

Reg' renewal of Models LS & MS Steam Traps. Other dwgs reg'd include: C1117B, C1117C.

This design was registered based on a technical review performed by the province of initial registration in accordance with the Association of Chief Inspectors policy on reciprocal recognition of design review.

Reviewer's Notes:

As required by CSA B51 4.2.1, this registration expires on February 25, 2026. This CRN is valid until the expiry date as long as the Manufacturer maintains a valid quality control program verified by an acceptable third-party agency until that date. Should the certification of the quality control program lapse before the expiry date, this registration shall become void.

Contact me if you have any questions. The invoice for registration will be forwarded under separate cover.

SHARON PETERS

boiler.designregistration@safetyauthority.ca
Design Administration

cc: