20 McAULAY COURT CHARLOTTE TOWN PEL CTA 9WY.

PO BOX 53 CHARLOTTETOWN PEI. C1A 7K1, PHONE: 902-566-1975, FAX: 902-566-3133

## RECOMMENDATION TO REGISTER - PRESSURE VESSEL DESIGN

To: Clarke Wolfe

DATE: 3/10/2009

From: ACI Central Inc.

Manufacturer:

Manufacturer #: PV 005

LaGrange Products 607 South Wayne Street PO Box 658 Fremont, IN 46737

## SUBJECT: ACI CENTRAL DESIGN REVIEW

The product described on this form has satisfied the minimum requirements for Review of pressure vessel designs established by the directors of ACI Central at their September 1994 meeting in Moncton New Brunswick. We recommend this Design be registered in your Jurisdiction under;

CRN:M5698.5

UNIT DESCRIPTION	DRAWING NUM	BER	SERVICE	DESIGN CODE		
Pump trap	1627-1446	1627-1446		ASME Sect VIII Div. 1		
SHEI	LSIDE		TUB	E SIDE		
MAWP @ TEMP	MDMT @ MAWP	MAV	VP @ TEMP	MOMT @ MAWP		

SHEL	LSIDE	7 12 14, 14,	
MAWP @ TEMP	MDMT @ MAWP	MAWP @ TEMP	MOMT @ MAWP
150 psi @ 650 F	-2- F @ 150 psi		

TEST PRES	SSURE: HYDRO: 1	95 psi @ 70	F	PNEU:	TEST F	RES	SURE: HY	ORO: PNEU:	
PAKI	WATERIAL			CA"	% EF	RT	PWHT	DIMENSIONS	NOTES
SHELL	SA 414 G	.1870	,187	.031	7			OD": 16	
HEADS	SA 414 G	.1630	163	.031	85			OAL" 27	
					<b>-</b>	1		W "	
					_			Н "	
ļ					_	1		HS FT2	

## NOTES:

- 1- THE RETURN OF THIS FORM, BEARING THE SIGNATURE AND STAMP OF THE JURISDICTION WILL LEGALLY ESTABLISH THE CRN SHOWN ON THIS FORM.
- 2- A COPY OF THE DESIGN BEARING THE CRN WILL BE SENT TO THE MANUFACTURER
- 3- DETAILS INCLUDING SERVICE CONDITIONS WILL BE POSTED ON THE "SILENT INSPECTOR" BULLETIN BOARD
- 4- COPIES OF THE DESIGN AND SPECIFICATIONS ARE AVAILABLE TO ACIC MEMBERS ON DEMAND.
- 5- THIS FORM WILL BE A PERMANENT ACIC RECORD.
- 6- TO REDUCE TURNAROUND TIME TO A MINIMUM FAX YOUR RESPONSE TO 902-566-3133.

ACIC LOG #: 10020

DESCRIPTION:

Horizontal pup trap. 16 " od \* 27" oal. Leg supported. ASME U stamp. NB number. This space is for jurisdictional stamp and signature

Nuñavut	NUMAVUT  Boilers and Pressure Vessels Act
CRN MSC Date MSC Signed	EGISTERED  13 09  Chief Inspector CB4

Sect. 2,0 - BPV Rev. 1 06/2003