

4. DRV AND ELECTRICAL PANEL ARE PREWIRED TO PROVIDE A SINGLE ELECTRICAL LANDING POINT AT THE PANEL.

NOTE(S):

## DECIMAL .XXXX ± .0005 .XXX ± .005 .XXX ± .015 .XX ± .015 .XX ± .015

DRAWN

RELEASED

.3

CFG

M	DESCR	IPTION	С	ONNECTION	
	COLD WATER INLET		2" NPT		
	MIXED WATER OUTLET			2" NPT	
	RE	CIRC WATER INLET		1-1/2" NPT	
	ST	EAM INLET (2)		2-1/2" NPT	
	C	ONDENSATE OUTLET (2)		1" NPT 813IB	
	EL	ECTRICAL PANEL		110 VAC @1.2A	
	DF	₹∨50		2" NPT	
	C	ONTROL VALVE (2)		1-1/2 NPT	
	TH	ERMOMETER(5)		1/2" NPT	
)	CI	P CONNECTION(4)		1" NPT	
	AIR VENT (2)			3/4" NPT	
2	VACUUM BREAKER (2)			1/2" NPT	
3	BYPASS TO DRAIN (2)			1" NPT	
1	BLOW DOWN(2)			1" NPT	
5	PRESSURE GAUGE (5)			1/4" NPT	
)	BLOWDOWN			3/4" NPT	
	ITEM		MA	MATERIAL	
	PIPING			COPPER TYPE "L"	
	EXCHANGER SHELL MATL.				
				ADMIRALTY BRASS	
		ARMSTRONG INTERNATIONAL Copyright © 2010 ARMSTRONG INTERNATIONAL, INC.			
		FRT535P50BS			
) DILG ®					
E	DATE	MATERIAL		SHEET 1 OF 1	
15	/18/2015		REV		
		CWF55983	C C	SALES	