



## **APPROVAL**

- ☐ APPROVED, PROCEED WITH FABRICATION
- ☐ APPROVED AS NOTED, PROCEED WITH FABRICATION IN ACCORDANCE WITH COMMENTS
- ☐ DISAPPROVED, DO NOT FABRICATE



## **DIGITAL FLO BOILER WATER/WATER PLATE &** FRAME HEAT EXCHANGER SINGLE WALL



51.5±1.0

PIPING AND COMPONENTS HIDDEN TO SHOW CONNECTIONS

(4A) 36.1 (4B) [917] 0 41.6 1057 20.6 523 2.5 63 63

## PROJECT NAME:


TAG:

| ITEM | DESCRIPTION                              | CONNECTION      |
|------|--|-----------------|
| 1    | COLD WATER INLET                         | 1-1/2" NPT      |
| 2    | MIXED WATER OUTLET                       | 1-1/2" NPT      |
| 3    | RECIRC WATER INLET                       | 1" NPT          |
| 4A   | PRIMARY(BOILER) INLET                    | 2" NPT          |
| 4B   | PRIMARY(BOILER) OUTLET                   | 2" NPT          |
| 5    | ELECTRICAL PANEL/BRAINSCAN               | 110VAC @ 1.2A   |
| 6    | DRV40                                    | 1-1/2" NPT      |
| 7    | N.C. ACTUATED BALL VALVE SAFETY SHUT OFF | 1-1/2" NPT      |
| 8    | THERMOMETER (3)                          |                 |
| 9    | CIP CONNECTION (2)                       | 1" NPT          |
| 10   | SRV(PRESSURE) PIPE TO DRAIN              | 1" NPT          |
| 11   | SRV(CONNECTION FOR USER SUPPLIED T&P)    | 3/4" NPT        |
|      |  |                 |
|      | ITEM                                     | MATERIAL        |
|      | PIPING                                   | COPPER TYPE "L" |
|      | EXCHANGER PLATE MATL.                    | T316L SS        |
|      | EXCHANGER GASKET MATL.                   | NITRILE         |
|      |  |                 |

## NOTE(S):

- 1. ALL DIMENSIONS +/- .5[13] UNLESS OTHERWISE SHOWN.
- 2. COMPLETE ASSEMBLY LEAD FREE COMPLIANT THE WETTED SURFACE OF THIS PRODUCT CONTACTED BY CONSUMABLE WATER CONTAINS LESS THAN ONE QUARTER OF ONE PERCENT (0.25%) OF LEAD BY WEIGHT.
- 3. PACKAGE INCLUDES ALL REQUIRED INLET CHECK VALVES AND STRAINERS ON DOMESTIC SIDE.
- 4. DRV, SAFETY SHUT OFF AND ELECTRICAL PANEL ARE PREWIRED TO PROVIDE A SINGLE ELECTRICAL LANDING POINT AT THE PANEL.

1935



.010

ARMSTRONG INTERNATIONAL Copyright (C) 2010 ARMSTRONG INTERNATIONAL, INC

DF35W40BS 1-1/2 NPT 1-1/2 NPT 1 NPT CPR

DATE CONFIG# (C-XXXXXX) 02/26/2013 MATERIAL **CFG** 

SHEET 1 OF 1

DRAWN DWG. D5XXXXX **SALES**