



APPROVAL

- ☐ APPROVED, PROCEED WITH FABRICATION
- ☐ APPROVED AS NOTED, PROCEED WITH FABRICATION IN ACCORDANCE WITH COMMENTS
- ☐ DISAPPROVED, DO NOT FABRICATE



DIGITAL FLO BOILER WATER/WATER PLATE & FRAME HEAT EXCHANGER SINGLE WALL



(4A) 36.1 (4B) [917] 0 41.6 1057 20.6 523 2.5 63 63


PROJECT NAME:

TAG:

DESCRIPTION	CONNECTION
COLD WATER INLET	1-1/2" NPT
MIXED WATER OUTLET	1-1/2" NPT
RECIRC WATER INLET	1" NPT
PRIMARY(BOILER) INLET	2" NPT
PRIMARY(BOILER) OUTLET	2" NPT
ELECTRICAL PANEL	110VAC @ 0.7A
DRV40	1-1/2" NPT
N.C. ACTUATED BALL VALVE SAFETY SHUT OFF	1-1/2" NPT
THERMOMETER (3)	
CIP CONNECTION (2)	1" NPT
SRV(PRESSURE) PIPE TO DRAIN	1" NPT
SRV(CONNECTION FOR USER SUPPLIED T&P)	3/4" NPT
ITEM	MATERIAL
PIPING	COPPER TYPE "L"
EXCHANGER PLATE MATL.	T316L SS
EXCHANGER GASKET MATL.	NITRILE
	MIXED WATER OUTLET RECIRC WATER INLET PRIMARY(BOILER) INLET PRIMARY(BOILER) OUTLET ELECTRICAL PANEL DRV40 N.C. ACTUATED BALL VALVE SAFETY SHUT OFF THERMOMETER (3) CIP CONNECTION (2) SRV(PRESSURE) PIPE TO DRAIN SRV(CONNECTION FOR USER SUPPLIED T&P) ITEM PIPING EXCHANGER PLATE MATL.

NOTE(S):

- 1. ALL DIMENSIONS +/- .5[13] UNLESS OTHERWISE SHOWN.
- 2. COMPLETE ASSEMBLY LEAD FREE COMPLIANT THE WETTED SURFACE OF THIS PRODUCT CONTACTED BY CONSUMABLE WATER CONTAINS LESS THAN ONE QUARTER OF ONE PERCENT (0.25%) OF LEAD BY WEIGHT.
- 3. PACKAGE INCLUDES ALL REQUIRED INLET CHECK VALVES AND STRAINERS ON DOMESTIC SIDE.
- 4. DRV, SAFETY SHUT OFF AND ELECTRICAL PANEL ARE PREWIRED TO PROVIDE A SINGLE ELECTRICAL LANDING POINT AT THE PANEL.



SALES

ARMSTRONG INTERNATIONAL Copyright (C) 2010 ARMSTRONG INTERNATIONAL, INC

DF35W40 1-1/2 NPT 1-1/2 NPT 1 NPT CPR

DATE CONFIG# (C-XXXXXX) 02/26/2013 MATERIAL **CFG**

SHEET 1 OF 1

DWG. D5XXXXX