

40.8±1.0

1037±25

60.6±1.0 [1540±25]

13.0


[331]

60.5±1.0 [1537±25]

26.9±1.0 [684±25]




☐ DISAPPROVED, DO NOT FABRICATE



DIGITAL FLO BOILER WATER/WATER PLATE & FRAME HEAT EXCHANGER SINGLE WALL





PROJECT NAME:

TAG:

ITEM	DESCRIPTION	CONNECTION	
1	COLD WATER INLET	2" NPT	
2	MIXED WATER OUTLET	2" NPT	
3	RECIRC WATER INLET 1-1/2" NPT		
4A	PRIMARY(BOILER) INLET 2" NPT		
4B	PRIMARY(BOILER) OUTLET 2" NPT		
5	ELECTRICAL PANEL 110VAC @ 0.7.		
6	DRV80 3" NPT		
7	N.C. ACTUATED BALL VALVE SAFETY SHUT OFF 2" NPT		
8	THERMOMETER (3)		
9	CIP CONNECTION (2) 1" NPT		
10	SRV(PRESSURE) PIPE TO DRAIN 1" NPT		
11	SRV(CONNECTION FOR USER SUPPLIED T&P)	3/4" NPT	
	ITEM	MATERIAL	
	PIPING	COPPER TYPE "L"	
	EXCHANGER PLATE MATL.	T316L SS	
	EXCHANGER GASKET MATL.	NITRILE	

NOTE(S):

55.9

1419

5

1. ALL DIMENSIONS +/- .5[13] UNLESS OTHERWISE SHOWN.

32.4

822


2. COMPLETE ASSEMBLY LEAD FREE COMPLIANT - THE WETTED SURFACE OF THIS PRODUCT CONTACTED BY CONSUMABLE WATER CONTAINS LESS THAN ONE QUARTER OF ONE PERCENT (0.25%) OF LEAD BY WEIGHT.

3.3

83

94.2 [2392]

- 3. PACKAGE INCLUDES ALL REQUIRED INLET CHECK VALVES AND STRAINERS ON DOMESTIC SIDE.
- 4. DRV, SAFETY SHUT OFF AND ELECTRICAL PANEL ARE PREWIRED TO PROVIDE A SINGLE ELECTRICAL LANDING POINT AT THE PANEL.



ARMSTRONG INTERNATIONAL Copyright (C) 2010 ARMSTRONG INTERNATIONAL, INC

DF65W50 2 NPT 2 NPT 1-1/2 NPT CPR

NAME	DATE	CONFIG# (C-XXXXX
CEG	02/26/2013	MATERIAL

SHEET 1 OF 1

DWG. D5XXXXX **SALES**